



- General Notes**
- DO NOT SCALE FROM THIS DRAWING. WORK ONLY FROM FIGURED DIMENSIONS.
 - ALL ERRORS & OMISSIONS TO BE REPORTED TO THE CONSULTING ENGINEER
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ARCHITECTS AND STRUCTURAL ENGINEERS DRAWINGS.
 - REFER TO DOCUMENT REGISTER FOR DESCRIPTION OF STATUS CODES.

- NOTES**
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS & CONTRACT DOCUMENTS.
 - THE MECHANICAL & ELECTRICAL CONTRACTORS SHALL BE RESPONSIBLE FOR THE CO-ORDINATION OF ALL UNDERGROUND SERVICES IN CONJUNCTION WITH THE MAIN CONTRACTOR.
 - THE CONTRACTOR IS TO ALLOW FOR THE SUPPLY AND INSTALLATION OF ACCESS CHAMBERS ON DUCTING IN ACCORDANCE WITH EIR SPECIFICATION.
 - ALL EIR DUCTING TO BE LOCATED IN FOOTPATHS & SOFT LANDSCAPING.
 - THIS INSTALLATION SHALL BE IN COMPLIANCE WITH "BUILDERS SPECIFICATION FOR EIR'S TELECOMS INFRASTRUCTURE REQUIREMENTS" DOCUMENT.
 - THE NUMBER OF HOUSES SERVED FROM A JOINT BOX (JB) IS MAXIMUM 10.
 - THE LEAD IN DUCT LENGTH FROM JOINT BOX TO EACH HOUSE IS TO BE MAXIMUM OF 80 METERS.
 - ALL JOINT BOXES ARE TO BE BUILT CLEAR OF DRIVEWAYS & OUTSIDE OWNER BOUNDARIES.
 - ALL SERVICE DUCTS ENTERING JOINT BOX ARE TO HAVE MINIMUM BENDS & PULL LENGTHS.
 - SERVICE DUCTS ARE NOT TO BE CUT. DUCTS TO BE LEFT COILED FOR CONTINUOUS RUN TO THE EXTERNAL TERMINATION UNIT OR INTERNAL TERMINATION POINT.
 - ANY SUBSEQUENT CHANGES TO THIS DRAWING LAYOUT ARE TO BE COMMUNICATED TO EIR TO FACILITATE TELECOMS INFRASTRUCTURE DESIGN CHANGES.
 - AT ALL TIMES THE CONTRACTOR IS TO BE AWARE OF THE PRESENCE OF EXISTING UNDERGROUND SERVICES IN THE VICINITY OF THE SITE
 - STANDARD DEPTHS AT WHICH DUCTS WILL BE BURIED UNDER CONCRETE OR BURIED SURFACES MEASURED FROM SURFACE LEVEL TO THE TOP OF THE BARREL OF THE DUCT SHALL BE 450MM WHEN LOCATED IN THE FOOTWAY OR 750MM WHEN LOCATED IN THE CARRIAGEWAY.
 - REFER TO INDIVIDUAL HOUSE LAYOUT DRAWINGS FOR EXACT METER/ETU LOCATIONS.

- EXISTING EIR UNDERGROUND DUCTING
- EXISTING EIR OVERHEAD LINES
- 37mm ID PIPE TO EACH HOUSE : LOW FRICTION, ROBUST
- NEW 110mmØ OPEN EIR UNDERGROUND DUCTING
- EIR JOINT BOX
- PROPOSED SITE EXTENTS

Rev	Status	Date	Description	D.E.
P01	S5	Dec '22	Issue For Part VIII	C.MD
P03	S2	July '22	Stage 2	C.MD
P02	S2	Mar '22	Issue For Information	C.MD
P01	S2	Dec '21	Issue For Information	C.MD

Revision	Project Drawing Reference			
P01	21798-VCE-XX-XX-DR-ME-1001			
Status	Varming Project Number			
S5	21798			
Date	Checked By	Drawn By	Scale	
DEC '21	J.G.	C.MD	1:100 @ A1	
Client				
GALWAY CITY COUNCIL CITY HALL, COLLEGE ROAD, GALWAY CITY, H91 X4K8				
Project Title				
DAY CENTRE FACILITIES AND EMERGENCY TEMPORARY HOMELESS ACCOMODATION SEAMUS QUIRKE ROAD, GALWAY CITY				

Drawing Title
**ELECTRICAL SERVICES
PROPOSED UTILITY SERVICES
INFRASTRUCTURE
OPEN EIR LAYOUT**



Dublin 01 4872300
Cork 021 2375080
Roscommon 090 6602380
Website www.varming.ie

ENGINEERS IRELAND
IHEEM
REGISTERED
MEMBER

Engineering for the Future