


THE INFORMATION ON THIS DRAWING IS TO THE TAILTE ÉIREANN - SURVEYING ITM COORDINATE SYSTEM



- LEGEND:**
- SITE BOUNDARY
 - EXISTING FOUL SEWER
 - PROPOSED FOUL SEWER
 - EXISTING STORM SEWER
 - PROPOSED STORM NETWORK
 - PROPOSED ROAD LEVELS
 - PROPOSED FINISHED FLOOR LEVELS
 - EXISTING 100mm uPVC WATERMAIN
 - PROPOSED 100mm uPVC WATERMAIN
 - PROPOSED WATER METER
 - PROPOSED FIRE HYDRANT
 - PROPOSED SLUICE VALVE
 - THRUST BLOCK
 - PROPOSED HOUSE FOUL CONNECTION
 - PROPOSED HOUSE WM CONNECTION
 - PROPOSED STORM NETWORK
 - DOMESTIC STORM SEWER CONNECTION & AJ
 - PROPOSED ROAD GULLY AND CONNECTION
 - UISCE ÉIREANN FOUL WAYLEAVE

D09	23.10.2025	Adjusted RLB	TA	RB
D08	08.09.2025	Draft for Planning	GM	RB
D07	01.05.2025	Draft Planning	DT	RB
D06	09.04.2025	Draft for Discussion	GM	RB
D05	01.04.2025	Draft for Discussion	GM	RB
D04	25/03/2025	Draft For Discussion	GM	RB
D03	28/02/2025	Draft For Discussion	GM	RB
D02	03.12.2024	Draft For Discussion	DT	GM
D01	2024.10.16	Issue for PCE	GM	RB
Rev	Date	Description	By	Chkd.

Client:  Comhairle Cathrach na Gaillimhe
Galway City Council

Project: **Proposed Social & Affordable Housing Scheme at Cappagh Road, Galway**

Title: **Site A
Proposed Services Layout**

Scale @ A1: **1:200**

Prepared by: GM Checked by: RB Date: Oct 2024

Drawing Status: Planning

TOBIN
Tel: +353 (0)91 565 211
Email: info@tobin.ie
www.tobin.ie

Drawing No.: **12031-2002** Revision: **D09**

- NOTES:**
- FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING.
 - ALL DRAWINGS TO BE CHECKED BY THE CONTRACTOR ON SITE.
 - ENGINEER/EMPLOYERS REPRESENTATIVE, AS APPROPRIATE, TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES BEFORE ANY WORK COMMENCES.
 - THE CONTRACTOR SHALL UNDERTAKE A THOROUGH CHECK FOR THE ACTUAL LOCATION OF ALL SERVICES/UTILITIES, ABOVE AND BELOW GROUND, BEFORE ANY WORK COMMENCES.
 - ALL LEVELS SHOWN RELATE TO ORDNANCE SURVEY DATUM AT MALIN HEAD.